

City of Medina			TTHM Stage 2 DBP Rule				Results in ppb MCL = 80	
Locational Running Annual Averages								
DATE	SITE 1	LRAA	SITE 2	LRAA	SITE 3	LRAA	Site 4	LRAA
10-Mar-15	24.5	42.0	21.2	41.1	22.5	44.3	27.0	29.2
10-Jun-15	43.4	40.0	39.0	39.1	41.8	42.2	47.0	26.7
8-Sep-15	53.0	37.6	58.1	36.2	49.5	35.0	63.5	42.6
8-Dec-15	36.6	39.4	33.7	38.0	31.7	36.4	41.6	44.8
9-Mar-16	45.6	44.7	32.6	40.9	32.9	39.0	35.6	46.9
8-Jun-16	54.8	47.5	54.8	44.8	60.7	43.7	67.9	52.2
14-Sep-16	71.8	52.2	60.2	45.3	55.2	45.1	72.1	54.3
14-Dec-16	27.7	50.0	23.7	42.8	25.0	43.5	29.1	51.2
8-Mar-17	38.8	48.3	38.9	44.4	39.3	45.1	45.0	53.5
13-Jun-17	47.6	46.5	49.3	43.0	45.5	41.3	53.6	50.0
13-Sep-17	58.8	43.2	56.8	42.2	51.6	40.4	58.0	46.4
12-Dec-17	30.9	44.0	30.6	43.9	31.6	42.0	35.8	48.1
12-Mar-18	31.0	42.1	28.6	41.3	27.9	39.2	29.3	44.2
12-Jun-18	56.0	44.2	54.8	42.7	54.9	41.5	67.1	47.6
12-Sep-18	58.9	44.2	57.1	42.8	55.8	42.6	63.6	49.0
13-Dec-18	33.8	44.9	31.2	42.9	30.8	42.4	34.7	48.7
12-Mar-19	26.6	43.8	22.6	41.4	21.9	40.9	25.4	47.7
11-Jun-19	62.8	45.5	51.1	40.5	45.5	38.5	52.9	44.2
10-Sep-19	69.0	48.1	55.9	40.2	48.9	36.8	58.2	42.8
10-Dec-19	32.0	47.6	31.8	40.4	29.6	36.5	31.4	42.0
10-Mar-20	27.2	47.8	27.3	41.5	25.6	37.4	29.4	43.0
9-Jun-20	43.1	42.8	43.7	39.7	45.6	37.4	47.8	41.7
8-Sep-20	67.6	42.5	58.1	40.2	50.6	37.9	67.3	44.0
10-Dec-20	36.8	43.7	32.9	40.5	30.5	38.1	30.1	43.7
10-Mar-21	25.6	43.3	23.6	39.6	23.6	37.6	24.3	42.4
9-Jun-21	47.1	44.3	43.5	39.5	37.2	35.5	42.5	41.1
8-Sep-21	72.1	45.4	71.7	42.9	66.2	39.4	77.0	43.5
8-Dec-21	36.5	45.3	33.1	43.0	30.4	39.4	36.8	45.2
14-Mar-22	31.1	46.7	30.7	44.8	27.8	40.4	31.6	47.0
8-Jun-22	50.3	47.5	47.9	45.9	45.8	42.6	50.3	48.9
15-Sep-22	68.1	46.5	58.4	42.5	57.2	40.3	65.3	46.0
15-Dec-22	28.8	44.6	30.4	41.9	28.6	39.9	33.5	45.2
16-Mar-23	40.3	46.9	31.2	42.0	30.1	40.4	36.5	46.4
15-Jun-23	44.3	45.4	37.2	39.3	37.2	38.3	46.4	45.4
15-Sep-23	75.1	47.1	65.6	41.1	60.9	39.2	71.4	47.0
14-Dec-23	28.6	47.1	20.0	38.5	19.0	36.8	22.2	44.1
14-Mar-24	27.8	44.0	22.5	36.3	22.2	34.8	25.1	41.3
13-Jun-24	47.3	44.7	37.6	36.4	44.3	36.6	45.2	41.0
12-Sep-24	72.3	44.0	50.8	32.7	47.4	33.2	66.0	39.6
20-Dec-24	28.4	44.0	22.8	33.4	20.5	33.6	27.4	40.9
13-Mar-25	25.6	43.4	24.2	33.9	22.5	33.7	27.1	41.4

TTHM Total Trihalomethane
 DBP Disinfection By-Product
 ppb parts per billion

MCL	Maximum Contaminate Level
-----	---------------------------

Site 1	300 W Reagan Parkway
--------	----------------------

Site 2	1010 Lafayette Rd
--------	-------------------

Site 3	S. Court Tank
--------	---------------

Site 4	100 High Point Dr.
--------	--------------------